



Ord. 688
 put XIV
 Herentals.
 Boordiam. 600 mm
 Boordiepte: 55 m - m.v.
 Grintomsorting:
 ϕ 1,2 - 1,7 mm
 filter perforatie 0,8 mm
 put. geplaatst: 12/9 '73.

Hoeveelheid: aange-
 vulde grint, 16.000 kg
 Aangevulde klei: ca. 12⁰⁰ m.

pompproef.

17/9 '73. Ruststand: pompput. 3.70:
 cap: 62⁰ m³. peilfilter 3.70:

17/9 '73. start	13 ⁰⁰ u. put	peilfilter
14 ⁰⁰	7.50	6.46
18 ⁰⁰	7.53	6.50
07 ⁰⁰	7.60	6.58
12 ⁰⁰	7.62	6.59
18 ⁰⁰	7.62	6.59
07 ⁰⁰	7.64	6.60
12 ⁰⁰	7.64	6.60